

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:223

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models 4090-9001, *-9001TSP, *-9001TTP, and *-9051 Supervised IAM Monitor Module; 4090-9002, *-9002TSP, and *-9002TTP IAM Relay Module; 4090-9106, *-9106TSP, and *-9106TTP Class "A" ZAM Initiating Module; 4090-9101, *-9101TSP, and *-9101TTP Class "B" ZAM Initiating Module; and 2190-9173 Two-Point I/O Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC
30 VDC for Models 4090-9002 series

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. For indoor use only. Refer to listee's Installation Instruction Manual for details.

*Rev. 09-25-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

SEPTEMBER 25, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager